



- ① MASTER SERVICE
- ② MASTER CURB BOX
- ③ MASTER TEE (SPLIT FOR INDIVIDUAL UNIT SERVICES)
- ④ INDIVIDUAL SERVICES—MINIMUM 1"
- ⑤ INDIVIDUAL CURB BOXES

NOTE

ALL SERVICE CONNECTIONS OF THIS TYPE SHALL BE REVIEWED BY RPU FOR PROPER SIZING PRIOR TO INSTALLATION. SERVICE FROM WATERMAIN TO BUILDING BY OWNER.

DEPARTMENT OF PUBLIC WORKS CITY OF ROCHESTER, MINNESOTA			
ALTERNATE SERVICE LAYOUT FOR MULTIPLE-UNIT BUILDINGS			
<i>Douglas C. Poring</i> RPU—WATER UTILITY		<i>Keith W. Friess</i> DIRECTOR	
SHT 1 OF 1 SHTS	DATE REVISED 6/15/07	PLATE NO. 6-13	REV. C